


ANCHOR BOLT M16 x 150mm



X - X
1:20

NET WEIGHT	OPERATING WEIGHT	LOADING POINT				
		P	R	T	Q	S
2730	7000	250	563	500	500	1125

UNIT: kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED	KM LIN	2007.07.03.	DWG TITLE:		TOWER FOUNDATION	
CHECKED	HUANG	2007.07.03.	DWG DETAIL:		FC-450	
			DWG NO.	AFC-0450-E2	SCALE	1:50
DRAWN	ZENG	2007.07.03.	SHENZHEN RYOWO COOLING TOWER CO.,LTD.			