



NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

NET WEIGHT	OPERATING WEIGHT	LOADING POINT			
		A	B	C	D
1365	3193	199.5	399	500	598.6

UNIT: Kg

	KM LIN	2007.05.18.	DWG TITLE: TOWER FOUNDATION		
CHECKED			DWG DETAIL: FRS-150-11		
	HUANG	2007.05.18.	DWG NO. AFRS-150-110-E0	SCALE	1:30
DRAWN	WEN	2007.05.18.	 SHENZHEN RYOWO COOLING TOWER CO.,LTD.		