



NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

NET WEIGHT	OPERATING WEIGHT	LOADING POINT			
		A	B	C	D
1322	3150	196.3	392.6	500	588.8

UNIT: Kg

	KM LIN	2007.05.18.	DWG TITLE: TOWER FOUNDATION	
CHECKED			DWG DETAIL: FRS-150-7.5	
	HUANG	2007.05.18.	DWG NO. AFRS-150-075-E0	SCALE 1:25
DRAWN	WEN	2007.05.18.	 SHENZHEN RYOWO COOLING TOWER CO.,LTD.	