



| NET WEIGHT | OPERATING WEIGHT | LOADING POINT | | | |
|------------|------------------|---------------|-------|-----|-------|
| | | A | B | C | D |
| 2114 | 5162 | 212 | 423.8 | 500 | 635.9 |

UNIT:Kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

| | | | | | | |
|---------|--------|-------------|---|-----------------|------------------|------|
| CHECKED | KM LIN | 2007.05.18. | DWG TITLE: | | TOWER FOUNDATION | |
| | HUANG | 2007.05.18. | DWG DETAIL: | | FRS-250-15 | |
| | | | DWG NO. | AFRS-250-150-E0 | SCALE | 1:30 |
| DRAWN | WEN | 2007.05.18. |  SHENZHEN RYOWO COOLING TOWER CO.,LTD. | | | |