



NET WEIGHT	OPERATING WEIGHT	LOADING POINT			
		A	B	C	D
7960	18000	524	1048.3	1400	1572.4

UNIT:Kg

- NOTES:
1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
 2. ANCHOR BOLT BY OTHERS.

APPROVED	HENG	2007.06.30	DWG TITLE:	TOWER FOUNDATION		
CHECKED	HENG	2007.06.30	DWG DETAIL:	FRS-610		
			DWG NO.	AFRS-610-E0	SCALE	1:60
DRAWN	PENG	2007.06.30	SHENZHEN RYOWO COOLING TOWER CO.,LTD.			