


A  
1:10

NET WELGHT	OPERATING WELGHT	LOADING POINT
540	1375	F
		459

- NOTES:
1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
  2. ANCHOR BOLT BY OTHERS.

APPROVED			DWG TITLE:	TOWER FOUNDATION		
CHECKED			DWG DETAIL:	FT-125		
DRAWN	ZENG	2007.08.20.	DWG NO.	AFT-0125-E0	SCALE	1:20
			 SHENZHEN RYOWO COOLING TOWER CO.,LTD.			