



A  
1:10

NET WELGHT	OPERATING WELGHT	LOADING POINT	
		F	T
900	2020	309	783

UNIT: kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED			DWG TITLE:	TOWER FOUNDATION		
CHECKED			DWG DETAIL:	FT-200		
			DWG NO.	AFT-0200-E0	SCALE	1:20
DRAWN	ZENG	2007.08.20.	SHENZHEN RYOWO COOLING TOWER CO.,LTD.			