



NET WELGHT	OPERATING WELGHT	LOADING POINT	
		F	T
1300	2760	413	1106

UNIT: kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED			DWG TITLE:	TOWER FOUNDATION		
CHECKED			DWG DETAIL:	FT-225		
DRAWN	ZENG	2007.08.20.	DWG NO.	AFT-0225-E0	SCALE	1:30
			RYOWO SHENZHEN RYOWO COOLING TOWER CO.,LTD.			