



NET WELGHT	OPERATING WELGHT	LOADING POINT	
		F	T
1350	2950	426	1143

UNIT: kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED			DWG TITLE:	TOWER FOUNDATION		
CHECKED			DWG DETAIL:	FT-250		
DRAWN	ZENG	2007.08.20.	DWG NO.	AFT-0250-E0	SCALE	1:30
			<b>RYOWO</b> SHENZHEN RYOWO COOLING TOWER CO.,LTD.			