


A
1:5

NET WELGHT	OPERATING WELGHT	LOADING POINT
		F
150	460	115

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED			DWG TITLE:	TOWER FOUNDATION		
CHECKED			DWG DETAIL:	FT-40		
			DWG NO.	AFT-0040-E0	SCALE	1:10
DRAWN	ZENG	2007.08.20.	 SHENZHEN RYOWO COOLING TOWER CO.,LTD.			