


ANCHOR BOLT M16 x 150mm




X - X
1:20

NET WEIGHT	OPERATING WEIGHT	LOADING POINT		
		P	R	T
1680	4040	268	617	500

UNIT:kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED	KM LIN	2007.07.03.	DWG TITLE:		TOWER FOUNDATION	
CHECKED	HUANG	2007.07.03.	DWG DETAIL:		FW-225	
			DWG NO.	AFW-0225-E2	SCALE	1:50
DRAWN	ZENG	2007.07.03.	 SHENZHEN RYOWO COOLING TOWER CO.,LTD.			