


NET WEIGHT	OPERATING WEIGHT	LOADING POINT				
		P	R	T	Q	S
2620	5805	214	450	500	427	899

UNIT: kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED	KM LIN	2007.07.03.	DWG TITLE:		TOWER FOUNDATION	
CHECKED	HUANG	2007.07.03.	DWG DETAIL:		FW-300	
			DWG NO.		AFW-0300-E2	SCALE
DRAWN	ZENG	2007.07.03.	 SHENZHEN RYOWO COOLING TOWER CO.,LTD.			