


NET WEIGHT	OPERATING WEIGHT	LOADING POINT				
		P	R	T	Q	S
3330	7600	268	619	500	537	1239

UNIT:kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED	KM LIN	2007.07.03.	DWG TITLE: TOWER FOUNDATION			
CHECKED	HUANG	2007.07.03.	DWG DETAIL: FW-500		SCALE	1:50
			DWG NO. AFW-0500-E2			
DRAWN	ZENG	2007.07.03.	 SHENZHEN RYOWO COOLING TOWER CO.,LTD.			