


ANCHOR BOLT M16 x 150mm



X - X
1:20

NET WEIGHT	OPERATING WEIGHT	LOADING POINT				
		P	R	T	Q	S
5020	11655	268	619	500	537	1239

UNIT: kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED	KM LIN	2007.07.03.	DWG TITLE:	TOWER FOUNDATION		
CHECKED	HUANG	2007.07.03.	DWG DETAIL:	FW-750		
			DWG NO.	AFW-0750-E2	SCALE	1:50
DRAWN	ZENG	2007.07.03.	SHENZHEN RYOWO COOLING TOWER CO.,LTD.			