



NET WEIGHT	OPERATING WEIGHT	LOADING POINT				
		P	R	T	Q	S
6620	15165	268	617	500	536	1235

UNIT: Kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED	KM LIN	2007.07.03.	DWG TITLE: TOWER FOUNDATION	
CHECKED	HUANG	2007.07.03.	DWG DETAIL: FW-900	
			DWG NO. AFW-0900-E2	SCALE 1:50
DRAWN	ZENG	2007.07.03.	 SHENZHEN RYOWO COOLING TOWER CO.,LTD.	