



NET WEIGHT	OPERATING WEIGHT	LOADING POINT				
		P	R	T	Q	S
3491	7293	245	574	500	491	1147

UNIT:kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED	KM LIN	2007.07.03.	DWG TITLE: TOWER FOUNDATION			
CHECKED	HUANG	2007.07.03.	DWG DETAIL: FWS-127-11x2			
			DWG NO.	AFWS-127-110x2-E1	SCALE	1:50
DRAWN	ZENG	2007.07.03.	SHENZHEN RYOWO COOLING TOWER CO.,LTD.			