


NET WEIGHT	OPERATING WEIGHT	LOADING POINT				
		P	R	T	Q	S
3192	9087	330.3	571.7	1870	660.6	1143.5

UNIT: Lbs

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED	KM LIN	2007.05.21.	DWG TITLE: TOWER FOUNDATION	
CHECKED	HUANG	2007.05.21.	DWG DETAIL: FWS-350-7.5	
			DWG NO. AFWS-350-7.5-E0	SCALE 1:60
DRAWN	PENG	2007.05.21.	 SHENZHEN RYOWO COOLING TOWER CO.,LTD.	