


X - X  
1:20

NET WEIGHT	OPERATING WEIGHT	LOADING POINT	
		A	B
2900	4970	310.6	2485

UNIT:Kg

- NOTES:
1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
  2. ANCHOR BOLT BY OTHERS.

APPROVED	HUANG	2006.06.30.	DWG TITLE:	TOWER FOUNDATION		
CHECKED	HUANG	2006.06.30.	DWG DETAIL:	FXS-350		
			DWG NO.	AFXS-0350-E0	SCALE	1:50
DRAWN	PENG	2006.06.30.	 SHENZHEN RYOWO COOLING TOWER CO.,LTD.			