



X - X
1: 20

NET WEIGHT	OPERATING WEIGHT	LOADING POINT	
		A	B
4325	8325	520.3	4162.5

UNIT:Kg

NOTES:

1. THE COOLING TOWER MUST BE LOCATED AT SUCH DISTANCE AND DIRECTION TO AVOID THE POSSIBILITY OF CONTAMINATED TOWER DISCHARGE AIR BEING DRAWN INTO BUILDING FRESH AIR INTAKES
2. ANCHOR BOLT BY OTHERS.

APPROVED	HUANG	2007.06.30	DWG TITLE:	TOWER FOUNDATION		
CHECKED	HUANG	2007.06.30	DWG DETAIL:	FXS-550		
			DWG NO.	AFXS-0550-E0	SCALE	1:50
DRAWN	PENG	2007.06.30	SHENZHEN RYOWO COOLING TOWER CO.,LTD.			